

SEMI-ANNUAL REPORT FOR INDUSTRIAL USERS REGULATED BY 40CFR 433

of this form is not an EPA/ADEQ requirement.

Attn: Water Div/NPDES Pretreatment

(1) IDENTIFYING INFORMATION

A. LEGAL NAME & MAILING ADDRESS

Everette Plating Inc
2570 Columbia 47
Magnolia Ar 71753

B. FACILITY & LOCATION ADDRESS

Everette Plating Inc
1920 S. Washington
Magnolia Ar. 71753

C. FACILITY CONTACT:

TELEPHONE NUMBER:

(2) REPORTING PERIOD—FISCAL YEAR From January 1 to December 31 (Both Semi-Annual Reports must cover Fiscal Year)

A. MONTHS WHICH REPORTS ARE DUE

January & July

B. PERIOD COVERED BY THIS REPORT

FROM: Jan 1 - 08 TO: June 30 / 08

(3) DESCRIPTION OF OPERATION

A. REGULATED PROCESSES

CORE PROCESS(ES)

CHECK EACH APPLICABLE BLOCK

- Electroplating
- Electroless Plating
- Anodizing
- Coating
- Chemical Etching and Milling
- Printed Circuit Board Manufacture

ANCILLARY PROCESS(ES)

LIST BELOW EACH PROCESS USED IN THE FACILITY

Passivation

B. CHANGES:

SUMMARIZE ANY CHANGES IN THE REGULATED PROCESSES SINCE THE LAST REPORT. ATTACH AN ADDITIONAL SHEET IF THE SPACE BELOW IS INADEQUATE. PROVIDE A NEW SCHEMATIC IF APPROPRIATE.

Rec'd via e-mail 11/11/08
Original could not be located.
violation noted & 2nd e-mail was sent 11/24/08

NPDES PERMIT FILE
NPDES # AR0043613
AFIN # _____

Permit PN _____
Correspondence _____
Technical Backup _____
Date Scanned 11/09/11

0CFR433.10(a) FOR 49 DIFFERENT OPERATIONS

Number of Regular Employees at this Facility

1 FT Employee

D. [Reserved]

11/14/08

Page 2 of 4
Everette Plating Inc.

(4) FLOW MEASUREMENT

INDIVIDUAL & TOTAL PROCESS FLOWS DISCHARGED TO POTW IN GALLONS PER DAY

Process	Average	Maximum	Type of Discharge
Regulated (Core & Ancillary)	<i>130</i>	<i>2100</i>	
Regulated (Cyanide)			
§403.6(e) Unregulated*			
§403.6(e) Dilute			
Cooling Water			
Sanitary	<i>35</i>	<i>100</i>	
Total Flow to POTW	<i>160</i>		*****

*"Unregulated" has a precise legal meaning; see 40CFR403.6(e).

(5) MEASUREMENT OF POLLUTANTS

A. TYPE OF TREATMENT SYSTEM

CHECK EACH APPLICABLE BLOCK

- Neutralization
- Chemical Precipitation and Sedimentation
- Chromium Reduction
- Cyanide Destruction
- Other *Filtration*
- None

B. COMMENTS ON TREATMENT SYSTEM

C. THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—CORE & ANCILLARY—(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE ANALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT ACCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT.

Pollutant(mg/l)	Cd	Cr	Cu	Pb	Ni	Ag	Zn	CN	TTO*
Max for 1 day	0.11	2.77	3.38	0.69	3.98	0.43	2.61	1.20	2.13
Monthly Ave	0.07	1.71	2.07	0.43	2.38	0.24	1.48	0.65	-
Max Measured	<i><0.002</i>	<i>0.896</i>	<i>0.500</i>	<i>0.280</i>	<i>0.296</i>	<i><0.005</i>	<i>0.342</i>	<i>0.012</i>	<i>exempt</i>
Ave Measured		↑			↑				

Sample Location *Outfall #1*

Sample Type (Grab or Composite) *Grab*

Number of Samples and Frequency Collected *2*

40CFR136 Preservation and Analytical Methods Use: Yes No

See Report from ETC dated 4/16 and 5-6/2008 enclosed

(6) CERTIFICATION

A. [Reserved]

[Reserved]

B. CHECK ONE: §433.11(e) TOXIC ORGANIC ANALYSIS ATTACHED §433.12(a) TTO CERTIFICATION

Based on my inquiry of the person or persons directly responsible for managing compliance with the pretreatment standard for total toxic organics (TTO), I certify that, to the best of my knowledge and belief, no dumping of concentrated toxic organics into the wastewaters has occurred since filing of the last semi-annual compliance report. I further certify that this facility is implementing the toxic organic management plan submitted to Arkansas Department of Environmental Quality.

Jimmy Chestham
(Typed Name)
Jimmy Chestham
(Corporate Officer or authorized representative)
Date of Signature 11 July 08

CORPORATE ACKNOWLEDGEMENT (Optional)

STATE OF ARKANSAS)
COUNTY OF _____)

Before me, the undersigned authority, on this day personally appeared _____ of _____ a corporation, known to me to be the person whose name is subscribed to the foregoing instrument(s), and acknowledged to me that he executed the same for purposes and considerations therein expressed, in the capacity therein stated and as the act and deed of said corporation.

Given under my hand and seal of office on this _____ day of _____, 200__.

Notary Public in and for _____
County, Arkansas

My commission expires _____

§6601 [42 U.S.C. 13101] Findings and Policy para (b) Policy.—The Congress hereby declares it to be the national policy of the United States that pollution should be prevented or reduced at the source whenever feasible; pollution that cannot be prevented should be recycled in an environmentally safe manner, whenever feasible; pollution that cannot be prevented or recycled should be treated in an environmentally safe manner whenever feasible; and disposal or other release into the environment should be employed only as a last resort and should be conducted in an environmentally safe manner.

The User may list any new or ongoing Pollution Prevention practices:

(8) GENERAL COMMENTS

(9) SIGNATORY REQUIREMENTS. [40CFR403.12(h)]

I certify under penalty of law that I have personally examined and am familiar with the information in this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Jimmy C. Heath
NAME OF CORPORATE OFFICER OR AUTHORIZED REPRESENTATIVE

President
OFFICIAL TITLE

Jimmy C. Heath
SIGNATURE

11 July 08
DATE SIGNED



ENVIRONMENTAL TESTING & CONSULTING, INC.

2700 Whitten Road Memphis, Tennessee 38113 (901) 213-2400 Fax (901) 213-2440
"A Laboratory Management Partner"

03694
Everette Plating
Mr. Jimmy Cheatham
2570 Columbia #7
Magnolia, AR 71753

Project ID :
Description : Semi-annual

Report Date : 4/22/2008

Report Number : 08-108-0251

REPORT OF ANALYSIS


Received : 4/17/2008

Lab No : 65042
Sample ID : Discharge Water

Matrix: Aqueous
Sampled: 4/16/2008 10:30

Test	Results	Units	MDL	Date / Time Analyzed	By	Analytical Method
Biochemical Oxygen Demand (5-day)	<6	mg/L	6	04/17/08 14:00	TB	SM-5210B-BOD
Oil and Grease	<1.8	mg/L	1.8	04/21/08 08:00	DJS	EPA-1664A
Total Aluminum	138	mg/L	0.5	04/21/08 12:51	JTR	EPA-200.7
Total Barium	0.023	mg/L	0.01	04/18/08 19:25	JTR	EPA-200.7
Total Cadmium	<0.002	mg/L	0.002	04/18/08 19:25	JTR	EPA-200.7
Total Chromium	5.01	mg/L	0.005	04/18/08 19:25	JTR	EPA-200.7
Total Copper	0.500	mg/L	0.005	04/18/08 19:25	JTR	EPA-200.7
Total Cyanide	0.012	mg/L	0.01	04/22/08 10:10	GD	SM-4500CNE
Total Lead	0.280	mg/L	0.006	04/18/08 19:25	JTR	EPA-200.7
Total Magnesium	0.258	mg/L	0.1	04/18/08 19:25	JTR	EPA-200.7
Total Manganese	0.032	mg/L	0.01	04/18/08 19:25	JTR	EPA-200.7
Total Mercury	<0.0002	mg/L	0.0002	04/22/08 11:40	TJ	EPA-245.1
Total Molybdenum	<0.005	mg/L	0.005	04/18/08 19:25	JTR	EPA-200.7
Total Nickel	0.296	mg/L	0.005	04/18/08 19:25	JTR	EPA-200.7
Total Silver	<0.005	mg/L	0.005	04/18/08 19:25	JTR	EPA-200.7
Total Suspended Solids	870	mg/L	20	04/21/08 10:40	CT	SM-2540D
Total Tin	<0.05	mg/L	0.05	04/18/08 19:25	JTR	EPA-200.7
Total Zinc	0.342	mg/L	0.01	04/18/08 19:25	JTR	EPA-200.7

Qualifiers/ Definitions MDL Method Quantitation Limit



ENVIRONMENTAL TESTING & CONSULTING, INC.

2790 Whitten Road Memphis, Tennessee 38133 (901) 213-2400 Fax (901) 213-2440
"A Laboratory Management Partner"

03694

Everette Plating
Mr. Jimmy Cheatham
2570 Columbia 47
Magnolia, AR 71753

Project ID :
Description : Semi-annual

Report Date : 5/12/2008

Report Number : 08-129-0262

REPORT OF ANALYSIS

Received : 5/8/2008

Lab No : 67407

Matrix: **Aqueous**

Sample ID : Discharge Water

Sampled: 5/6/2008 0:00

Test	Results	Units	MQL	Date / Time Analyzed	By	Analytical Method
Total Chromium	0.896	mg/L	0.005	05/12/08 00:48	JTR	EPA-200.7

Qualifiers/
Definitions MQL Method Quantitation Limit