

SEMI-ANNUAL REPORT FOR INDUSTRIAL USERS REGULATED BY 40CFR433

Use of this form is not an EPA/ADEQ requirement.

Att: Water Div/NPDES Pretreatment

(1) IDENTIFYING INFORMATION	
A. LEGAL NAME & MAILING ADDRESS <i>Everette Plating Inc 2570 Columbia #7 Magnolia Av. 71953</i>	B. FACILITY & LOCATION ADDRESS <i>Everette Plating Inc 1920 S. Washington Magnolia Av 71953</i>
C. FACILITY CONTACT:	TELEPHONE NUMBER:
(2) REPORTING PERIOD - FISCAL YEAR From January 1 to December 31 (Both Semi-Annual Reports must cover Fiscal Year)	
A. MONTHS WHICH REPORTS ARE DUE <i>January & July</i>	B. PERIOD COVERED BY THIS REPORT FROM <i>July 1-08</i> TO: <i>Dec. 31-08</i>
(3) DESCRIPTION OF OPERATION	
<p>A. REGULATED PROCESSES</p> <p><u>CORE PROCESS(ES)</u></p> <p>CHECK EACH APPLICABLE BLOCK:</p> <p><input type="checkbox"/> Electroplating <input type="checkbox"/> Electroless Plating <input checked="" type="checkbox"/> Anodizing <input type="checkbox"/> Coating <input type="checkbox"/> Chemical Etching and Milling <input type="checkbox"/> Printed Circuit Board Manufacture</p> <p><u>ANCILLARY PROCESS(ES)</u></p> <p>LIST BELOW EACH PROCESS USED IN THE FACILITY:</p> <p><i>Passivation</i> <i>Conversion Coating</i></p>	<p>B. CHANGES: SUMMARIZE ANY CHANGES IN THE REGULATED PROCESSES SINCE THE LAST REPORT. ATTACH AN ADDITIONAL SHEET IF THE SPACE BELOW IS INADEQUATE. PROVIDE A NEW SCHEMATIC IF APPROPRIATE.</p> <p><i>rec'd via e-mail on 1/21/09 compliant, no action necessary</i></p> <p>NPDES PERMIT FILE NPDES # <u>AR0043613</u> AFIN # _____ Permit PN _____ Correspondence _____ Technical Backup _____ <u>11/07/09</u> Date Scanned</p>
C. Number of Regular Employees at this Facility <i>1 FT. employee</i>	D. [Reserved]

Everett Plating

(4) FLOW MEASUREMENT

INDIVIDUAL & TOTAL PROCESS FLOWS DISCHARGED TO POTW IN GALLONS PER DAY

Process	Average	Maximum	Type of Discharge
Regulated (Core &	<i>113</i>	<i>900</i>	
Regulated (Cyanide)			
§403.6(e) Unregulated*			
§403.6(e) Dilute			
Cooling Water			
Sanitary	<i>30</i>	<i>95</i>	
Total Flow to POTW	<i>143</i>		*****

*"Unregulated" has a precise legal meaning; see 40CFR403.6(e).

(5) MEASUREMENT OF POLLUTANTS

A. TYPE OF TREATMENT SYSTEM

CHECK EACH APPLICABLE BLOCK

- Neutralization
- Chemical Precipitation and Sedimentation
- Chromium Reduction
- Cyanide Destruction
- Other *filtration & ion exchange*
- None

B. COMMENTS ON TREATMENT SYSTEM

C. THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES—CORE & ANCILLARY—(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE ANALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT ACCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT.

Pollutant(mg/l)	Cd	Cr	Cu	Pb	Ni	Ag	Zn	CN	TTO*
Max for 1 day	0.11	2.77	3.38	0.69	3.98	0.43	2.61	1.20	2.13
Monthly Ave	0.07	1.71	2.07	0.43	2.38	0.24	1.48	0.65	—
Max Measured	<i><0.002</i>	<i>0.116</i>	<i>0.021</i>	<i><0.006</i>	<i>0.014</i>	<i><0.005</i>	<i>0.029</i>	<i>(0.01)</i>	<i>exempt</i>
Ave Measured									

Sample Location *outfall #1*

Sample Type (Grab or Composite) *Grab*

Number of Samples and Frequency Collected *1 on Oct 29*

40CFR136 Preservation and Analytical Methods Use: Yes No

See Report from ETC dated Oct 21, 09 enclosed

(6) CERTIFICATION

A. [Reserved]

[Reserved]

B. CHECK ONE: §433.11(e) TOXIC ORGANIC ANALYSIS ATTACHED §433.12(a) TTO CERTIFICATION

Based on my inquiry of the person or persons directly responsible for managing compliance with the pretreatment standard for total toxic organics (TTO), I certify that, to the best of my knowledge and belief, no dumping of concentrated toxic organics into the wastewaters has occurred since filing of the last semi-annual compliance report. I further certify that this facility is implementing the toxic organic management plan submitted to Arkansas Department of Environmental Quality.

Jimmy Chestnut
(Typed Name)
Jimmy Chestnut
(Corporate Officer or authorized representative)
Date of Signature 26 Jan 07

CORPORATE ACKNOWLEDGEMENT (Optional)

STATE OF ARKANSAS)
COUNTY OF _____)

Before me, the undersigned authority, on this day personally appeared _____ of _____ a corporation, known to me to be the person whose name is subscribed to the foregoing instrument(s), and acknowledged to me that he executed the same for purposes and considerations therein expressed, in the capacity therein stated and as the act and deed of said corporation.

Given under my hand and seal of office on this _____ day of _____, 200_____.

Notary Public in and for _____
County, Arkansas

My commission expires _____

(6002 [42 U.S.C. 13101] Findings and Policy (a)(1) Policy - The Congress hereby declares it to be the national policy of the United States that pollution should be prevented or reduced at the source whenever feasible; pollution that cannot be prevented should be recycled in an environmentally safe manner; whenever feasible, pollution that cannot be prevented or recycled should be treated in an environmentally safe manner whenever feasible; and disposal or other release into the environment should be employed only as a last resort and should be conducted in an environmentally safe manner.

The User may list any new or ongoing Pollution Prevention practices:

(8) GENERAL COMMENTS

(9) SIGNATORY REQUIREMENTS [40CFR403.12(l)]

I certify under penalty of law that I have personally examined and am familiar with the information in this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Jeremy C. Cheetham
NAME OF CORPORATE OFFICER OR AUTHORIZED REPRESENTATIVE
President
OFFICIAL TITLE

Jeremy C. Cheetham
SIGNATURE
20 Jan 09
DATE SIGNED



ENVIRONMENTAL TESTING & CONSULTING, Inc.

2790 Witten Road Memphis, Tennessee 38133 (901) 215-2400 Fax: (901) 215-2440
A Laboratory Management Practice

03694

Everette Plating
Mr. Jimmy Cheatham
2570 Columbia A7
Magnolia, AR 71753

Project ID :
Description : Semi-annual

Report Date : 11/10/2008

Report Number : 08-304-0208

REPORT OF ANALYSIS

Received : 10/30/2008

Lab No : 86042

Matrix: Aqueous

Sample ID : Discharge Water

Sampled: 10/29/2008 9:30

Test	Results	Units	MQL	Date / Time Analyzed	By	Analytical Method
Total Aluminum	4.21	mg/L	0.1	11/03/08 21:54	JTR	EPA-200.7
Total Barium	<0.01	mg/L	0.01	11/03/08 21:54	JTR	EPA-200.7
Biochemical Oxygen Demand (5-day)	<12	mg/L	12	10/30/08 14:00	JTR	SM-5210B-BOD
Total Cadmium	<0.002	mg/L	0.002	11/03/08 21:54	JTR	EPA-200.7
Total Chromium	0.116	mg/L	0.005	11/03/08 21:54	JTR	EPA-200.7
Total Copper	0.021	mg/L	0.005	11/03/08 21:54	JTR	EPA-200.7
Total Cyanide	<0.01	mg/L	0.01	11/03/08 00:00	GU	SM-4500CNE
Total Lead	<0.006	mg/L	0.006	11/03/08 21:54	JTR	EPA-200.7
Total Magnesium	<0.1	mg/L	0.1	11/03/08 21:54	JTR	EPA-200.7
Total Manganese	<0.01	mg/L	0.01	11/03/08 21:54	JTR	EPA-200.7
Total Mercury	<0.0002	mg/L	0.0002	11/05/08 14:46	TJ	EPA-245.1
Total Molybdenum	<0.005	mg/L	0.005	11/03/08 21:54	JTR	EPA-200.7
Total Nickel	0.014	mg/L	0.005	11/03/08 21:54	JTR	EPA-200.7
Oil and Grease	<1.7	mg/L	1.7	11/04/08 12:15	NFT	EPA-1664A
Total Silver	<0.005	mg/L	0.005	11/03/08 21:54	JTR	EPA-200.7
Total Suspended Solids	21	mg/L	2	10/31/08 15:10	NFP	SM-2540D
Total Tin	<0.05	mg/L	0.05	11/03/08 21:54	JTR	EPA-200.7
Total Zinc	0.029	mg/L	0.01	11/02/08 21:54	JTR	EPA-200.7

Qualifiers / Definitions MQL Method Quantitation Limit