

Allen

USE OF THIS FORM IS NOT AN NPDES REQUIREMENT

(1) IDENTIFYING INFORMATION

A. LEGAL NAME & MAILING ADDRESS

Everette Plating Inc  
2570 Columbia #7  
Magnolia Ark. 71753

B. FACILITY & LOCATION ADDRESS

Everette Plating Inc  
1920 S. Washington  
Magnolia Ark. 71753

C. FACILITY CONTACT:

TELEPHONE NUMBER: 870 695-3600

(2) REPORTING PERIOD--FISCAL YEAR From January 1 to December 31 (Both Semi-Annual Reports must cover Fiscal Year)

A. MONTHS WHICH REPORTS ARE DUE

July & January

B. PERIOD COVERED BY THIS REPORT

FROM: Jan 1 - 09 TO: June 30 - 09

(3) DESCRIPTION OF OPERATION

A. REGULATED PROCESSES

CORE PROCESS(ES)

CHECK EACH APPLICABLE BLOCK

- Electroplating
- Electroless Plating
- Anodizing
- Coating
- Chemical Etching and Milling
- Printed Circuit Board Manufacture

ANCILLARY PROCESS(ES)\*

LIST BELOW EACH PROCESS USED IN THE FACILITY

Passivation  
Conversion Coating

B. CHANGES:

SUMMARIZE ANY CHANGES IN THE REGULATED PROCESSES SINCE THE LAST REPORT. ATTACH AN ADDITIONAL SHEET IF THE SPACE BELOW IS INADEQUATE. PROVIDE A NEW SCHEMATIC IF APPROPRIATE.

Complete & compliant  
No action necessary  
# 7051

JUL 15 2009

VH

NPDES PERMIT FILE  
NPDES # AR0043613  
AFIN #  
Permit PN  
Correspondence  
Technical Backup  
Date Scanned  
7/28/09 VH

\*SEE 40CFR433.10(a) FOR 40 DIFFERENT OPERATIONS

C. Number of Regular Employees at this Facility

1 FTE employee

D. [Reserved]

Everette

2 of 5

(4) FLOW MEASUREMENT

INDIVIDUAL & TOTAL PROCESS FLOWS DISCHARGED TO POTW IN GALLONS PER DAY

Process	Average	Maximum	Type of Discharge
Regulated (Core & Regulated (Cyanide)	115	1000	
§403.6(e) Unregulated*			
§403.6(e) Dilute			
Cooling Water			
Sanitary	32		
Total Flow to POTW	143		*****

\*"Unregulated" has a precise legal meaning; see 40CFR403.6(e).

(5) MEASUREMENT OF POLLUTANTS

A. TYPE OF TREATMENT SYSTEM

CHECK EACH APPLICABLE BLOCK

- Neutralization
- Chemical Precipitation and Sedimentation
- Chromium Reduction
- Cyanide Destruction
- Other Filtration & ion exchange resin
- None

B. COMMENTS ON TREATMENT SYSTEM

C. THE INDUSTRIAL USER MUST PERFORM SAMPLING AND ANALYSIS OF THE EFFLUENT FROM ALL REGULATED PROCESSES--CORE & ANCILLARY--(AFTER TREATMENT, IF APPLICABLE). ATTACH THE LAB ANALYSIS WHICH SHOWS A MAXIMUM; TABULATE ALL THE ANALYTICAL DATA COLLECTED DURING THE REPORT PERIOD IN THE SPACE PROVIDED BELOW. ZERO CONCENTRATIONS ARE NOT ACCEPTABLE; LIST THE DETECTION LIMIT IF CONCENTRATION WAS BELOW DETECTION LIMIT.

Pollutant(mg/l)	Cd	Cr	Cu	Pb	Ni	Ag	Zn	CN	TTO*
Max for 1 day	0.11	2.77	3.38	0.69	3.98	0.43	2.61	1.20	2.13
Monthly Ave	0.07	1.71	2.07	0.43	2.38	0.24	1.48	0.65	-
Max Measured	<0.002	0.816	0.075	0.031	0.082	<0.005	0.074	<0.010	exempt.
Ave Measured									

Sample Location Outfall #1

Sample Type (Grab or Composite) Grab.

Number of Samples and Frequency Collected 1 31-Mar 09.

40CFR136 Preservation and Analytical Methods Use:  Yes  No

(6) CERTIFICATION

A. [Reserved]

*Everett Plating*

[Reserved]

B. CHECK ONE:  §433.11(e) TOXIC ORGANIC ANALYSIS ATTACHED  §433.12(a) TTO CERTIFICATION

Based on my inquiry of the person or persons directly responsible for managing compliance with the pretreatment standard for total toxic organics (TTO), I certify that, to the best of my knowledge and belief, no dumping of concentrated toxic organics into the wastewaters has occurred since filing of the last semi-annual compliance report. I further certify that this facility is implementing the toxic organic management plan submitted to Arkansas Department of Environmental Quality.

Jimmy C. Cheatham  
(Typed Name)

Jimmy C. Cheatham  
(Corporate Officer or authorized representative)

Date of Signature 13 July 09.

**CORPORATE ACKNOWLEDGEMENT (Optional)**

STATE OF ARKANSAS )  
COUNTY OF \_\_\_\_\_ )

Before me, the undersigned authority, on this day personally appeared \_\_\_\_\_ of \_\_\_\_\_,

a corporation, known to me to be the person whose name is subscribed to the foregoing instrument(s), and acknowledged to me that he executed the same for purposes and considerations therein expressed, in the capacity therein stated and as the act and deed of said corporation.

Given under my hand and seal of office on this \_\_\_\_\_ day of \_\_\_\_\_, 200\_\_.

\_\_\_\_\_  
Notary Public in and for \_\_\_\_\_  
County, Arkansas

46/5

§6602 [42 U.S.C. 13101] Findings and Policy para (b) Policy.--The Congress hereby declares it to be the national policy of the United States that pollution should be prevented or reduced at the source whenever feasible; pollution that cannot be prevented should be recycled in an environmentally safe manner, whenever feasible; pollution that cannot be prevented or recycled should be treated in an environmentally safe manner whenever feasible; and disposal or other release into the environment should be employed only as a last resort and should be conducted in an environmentally safe manner.

The User may list any new or ongoing Pollution Prevention practices:

(8) GENERAL COMMENTS

(9) SIGNATORY REQUIREMENTS [40CFR403.12(D)]

I certify under penalty of law that I have personally examined and am familiar with the information in this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Jimmy C. Cheatham  
NAME OF CORPORATE OFFICER OR AUTHORIZED REPRESENTATIVE  
President  
OFFICIAL TITLE

Jimmy C. Cheatham  
SIGNATURE  
13 July 09.  
DATE SIGNED

Analysis report attached



# ENVIRONMENTAL TESTING & CONSULTING, INC.

2790 Whitten Road Memphis, Tennessee 38133 (901) 213-2400 Fax (901) 213-2440  
"A Laboratory Management Partner"

5 of 5

03694  
Everette Plating  
Mr. Jimmy Cheatham  
2570 Columbia 47  
Magnolia, AR 71753

Project ID :  
Description : Semi-annual

Report Date : 4/8/2009

Report Number : 09-091-0220

## REPORT OF ANALYSIS

Received : 4/1/2009

Lab No : 59761  
Sample ID : Discharge Water

Matrix: Aqueous  
Sampled: 3/31/2009 0:00

Test	Results	Units	ML	Date / Time Analyzed	By	Analytical Method
Total Aluminum	23.3	mg/L	0.100	04/02/09 19:39	JTR	EPA-200.7
Total Barium	<0.010	mg/L	0.010	04/02/09 19:39	JTR	EPA-200.7
Total Cadmium	<0.002	mg/L	0.002	04/02/09 19:39	JTR	EPA-200.7
Total Chromium	0.816	mg/L	0.005	04/02/09 19:39	JTR	EPA-200.7
Total Copper	0.075	mg/L	0.005	04/02/09 19:39	JTR	EPA-200.7
Total Cyanide	<0.010	mg/L	0.010	04/02/09 09:50	GD	SM-4500CNE
Total Lead	0.031	mg/L	0.006	04/02/09 19:39	JTR	EPA-200.7
Total Magnesium	0.933	mg/L	0.100	04/02/09 19:39	JTR	EPA-200.7
Total Manganese	0.025	mg/L	0.010	04/02/09 19:39	JTR	EPA-200.7
Total Mercury	<0.0002	mg/L	0.0002	04/08/09 14:26	TJ	EPA-245.1
Total Molybdenum	<0.005	mg/L	0.005	04/02/09 19:39	JTR	EPA-200.7
Total Nickel	0.082	mg/L	0.005	04/02/09 19:39	JTR	EPA-200.7
Total Silver	<0.005	mg/L	0.005	04/02/09 19:39	JTR	EPA-200.7
Total Tin	<0.050	mg/L	0.050	04/02/09 19:39	JTR	EPA-200.7
Total Zinc	0.074	mg/L	0.010	04/02/09 19:39	JTR	EPA-200.7

Qualifiers/ Definitions    MQL    Method Quantitation Limit