

Henderson, Katie

From: Gilliam, Allen
Sent: Thursday, September 09, 2010 1:17 PM
To: 'gerry.eddy@sapagroup.com'
Cc: Henderson, Katie; magnolia russell thomas
Subject: SAPA (ARP000004) July 2010 Semi-annual Pretreatment Report, Closure and Review (Magnolia AR0043613)

Gerry,

Your July semi-annual report was reviewed, deemed complete and compliant with 40 CFRs 467 and 403.

It's understood by your report SAPA has shut down all of its regulated Aluminum Forming processes on site, is no longer generating nor discharging regulated wastewater to the City of Magnolia's sewage collection system.

Your file will be "closed" with no further semi-annual reports with analytical results necessary due to this office.

Keep in mind, if circumstances (hopefully) change and any of your Aluminum Forming operations should be re-activated with wastewater generated to be discharged to the city, you must report this intent.

This is required under 40 CFR 403.12(j) "Notification of changed Discharge. All Industrial Users shall promptly notify [ADEQ] (and the POTW if the POTW is not the Control Authority) in advance of any substantial change in the volume or character of pollutants in their Discharge, including the listed or characteristic hazardous wastes for which the Industrial User has submitted initial notification under paragraph (p) of this section."

It was a pleasure working with you as a cooperative, open-door stakeholder within this State's Pretreatment Program.
I hope the economy turns around soon in your company's favor.

Sincerely,

Allen Gilliam
ADEQ State Pretreatment Coordinator
501.682.0625

ec: Katie Henderson/E-drive/"Pretreatment Reports"
Russell Thomas/Magnolia Wastewater System Superintendent