Arkansas Department of Environmental Quality
UST Compliance Inspection Checklist

A. Ownership of Tank(s)

Owner Name (Corporation, individual, Public Agency, or other entity): Entergy Arkansas
Street Address: 425 W. Capitol Ave
County: Pulaski
City: Little Rock State: AR Zip Code: 72203
Area Code: 870 Phone Number: 698-4517
Contact Person At UST Location: Kellee Fletcher Phone #:

B. Location of Tank(s)

(If Same as Section 1, check here ☐)
Facility Name or Company Site identifier, as applicable: Entergy AR- Independence Plant
Street address or State Road, as applicable: 555 Point Ferry Rd.
City (nearest): Newak State: Arkansas Zip Code: 72562
County: Independence Lat.:
Number of Tanks at This Location: 2 Long.:
Facility ID#: 32000025

C. Tank Information

(1) Tank(s) presently in use	Tank# 1	Tank# 2	Tank#	Tank#
(2) If not in use, date last used				
(3) If emptied, verify 1" or less of product in tank				
(4) Month and Year Tank Installed (E-estimate or K-known)	1991	1991		
(5) Material of Construction (E-estimate or K-known)	FRP	FRP		
(6) Capacity of Tank (in gallons)(E-estimate or K-known)	15,000	2,500		
(7) Substance Stored (E-estimate or K-known)	diesel	gasoline		

D. Release Detection For Tanks

Release detection method is present for tank(s). [1] Yes ☑ No ☐ NA ☐
If Yes, select method below. If NA, explain:

(1) Manual Tank Gauging	☐	☐	☐	☐
(2) Tank Tightness Testing and Inventory Control	☐	☐	☐	☐
(3) Automatic Tank Gauging	☐	☐	☐	☐
(4) Vapor Monitoring	☐	☐	☐	☐
(5) Groundwater Monitoring	☐	☐	☐	☐
(6) Interstitial Monitoring	☑	☑	☐	☐
(7) Other approved method (write in name of method)				

E. Release Detection For Piping

Release detection method is present for piping. [1] Yes ☐ No ☐ NA ☐
If Yes, select method below. If NA, explain:

(1) Check Type of Piping for each Tank	Pressure Pipe	☐	☐	☐	☐
	Suction Pipe	☑	☑	☐	☐
(2) FOR PRESSURE PIPING: Automatic Line Leak Detectors, and (check one)					
(a) Vapor Monitoring		☐	☐	☐	☐
(b) Groundwater Monitoring		☐	☐	☐	☐
(c) Secondary Containment With Interstitial Monitoring		☐	☐	☐	☐
(d) Line Tightness Testing		☐	☐	☐	☐
(e) Other approved method (write in name of method)					

F. Financial Assurance

(1) Petroleum Storage Tank Trust Fund (PSTTF)? (check one) Yes ☐ No ☐ N/A ☑ If No or N/A for PSTTF, mechanism for meeting financial

(2) Can PSTTF deductible be satisfied? Yes ☐ No ☐ N/A ☑ responsibility?

(1) Release detection system meets the performance standards in 280.43 or 280.44. [3] Yes ☑ No ☐ NA ☐

(2) Implementing agency has been notified of suspected release as required. [4] Yes ☐ No ☐ NA ☑

(3) Hazardous substance UST system release detection meets the requirements (i.e., either secondarily contained or otherwise approved by the implementing agency). [6] Yes ☐ No ☐ NA ☑

(4) Release detection requirements are complied with (i.e., method present, operational, release investigated and reported as required) for UST systems containing product. [7] Yes ☑ No ☐ NA ☐

Inspector's Signature: Signed with SignDoc Signed on 2008-04-23 12:05:41

Date: Apr 23, 2008