

**ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
UST COMPLIANCE INSPECTION CHECKLIST**

A. Ownership of Tank(s)	B. Location of Tank(s)
(If same as "Owner", check here: <input type="checkbox"/>)	
Owner Name (Corporation, Individual, Public Agency, or other entity)	Facility Name or Company Site Identifier, as applicable
Street Address	Street Address or State Road, as applicable
County	County
City, State Zip	City (nearest), State Zip
Phone Number	Phone Number
Contact Person at UST Location: _____	Number of Tanks at This Location: _____
Phone Number: _____	Registration certificate posted in a conspicuous location: <input type="checkbox"/> Yes <input type="checkbox"/> No

C. Tank Information

(1) Tank(s) presently in use	Tank # _____	Tank # _____	Tank # _____	Tank # _____
(2) If not in use, date last used				
(3) If emptied, verify 1" or less of product in tank				
(4) Month and Year Tank Installed (E-estimate or K-known)				
(5) Material of Construction (E-estimate or K-known)				
(6) Capacity of Tank (in gallons) (E-estimate or K-known)				
(7) Substance Stored (E-estimate or K-known)				

D. Release Detection For Tanks

Release detection system must meet the performance standards in 280.43 or 280.44

(1) Automatic Tank Gauging	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) Vapor Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) Groundwater Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(4) Statistical Inventory Reconciliation (SIR)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(5) Secondary Containment With Interstitial Monitoring (required on piping installed after July 1, 2007)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(6) Other approved method (write in name of method)				

E. Release Detection For Piping

Release detection system must meet the performance standards in 280.43 or 280.44

(1) Check Type of Piping for each Tank	Pressure Pipe	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Suction Pipe	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) FOR PRESSURE PIPING: Automatic Line Leak Detectors, <u>and</u> (check one)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(a) Vapor Monitoring		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(b) Groundwater Monitoring		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(c) Secondary Containment With Interstitial Monitoring (required on piping installed after July 1, 2007)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(d) Line Tightness Testing		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(e) Other approved method (write in name of method)					

COMPLIANCE INSPECTION CHECKLIST

Date: _____

Please save your changes before proceeding.

Facility ID: _____ AFIN: _____ Facility Name: _____

RELEASE DETECTION FOR PIPING**Pressurized Piping**

A method must be selected from each set. Where applicable indicate date of last test.

Set 1	Tank # _____	Tank # _____	Tank # _____	Tank # _____
(1) Automatic Flow Restrictor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) Automatic Shut-off Device	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) Continuous Alarm System	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
and				
Set 2				
(4) Annual Line Tightness Testing				
(5) Vapor Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(6) If Vapor Monitoring, documentation of monthly monitoring is available?				
(7) Interstitial Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(8) If Interstitial Monitoring, documentation of monthly monitoring is available?				
(9) Groundwater Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(10) If Groundwater Monitoring, documentation of monthly monitoring is available?				
(11) Other Approved Method (specify in comments)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Suction Piping

Indicate date of most recent test.

(12) Line Tightness Testing (required every 3 years)				
(13) Vapor Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(14) Secondary Containment with Interstitial Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(15) Groundwater Monitoring	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(16) Other Approved Method (specify in comments)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(17) No Leak Detection Required? (must answer yes to all of the following questions)				
(a) Operates at less than atmospheric pressure	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(b) Has only one check valve, which is located directly under pump	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(c) Slope of piping allows product to drain back into tank when suction released	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(d) All information on suction piping is verifiable	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

RELEASE DETECTION FOR PIPING CHECKLIST

Date: _____

Please save your changes before proceeding.

Facility ID: _____ AFIN: _____ Facility Name: _____

RELEASE PREVENTION**Check (√) for compliance; “No” for noncompliance. Leave blank for “N/A”.**

I. SPILL PREVENTION	Tank # _____	Tank # _____	Tank # _____	Tank # _____
(1) Spill prevention device present and operational.				
(2) Spill prevention device in good repair.				
(3) Spill prevention device has no significant debris or liquid.				
(4) Spill prevention device is tested at least every three years, or is double walled and periodically monitored.				
II. OVERFILL PREVENTION				
(1) Overfill prevention device present and operational.				
A. Automatic shutoff device.				
(1) Verified by observations.				
(2) Automatic shutoff device is functional and operational.				
(3) Automatic shutoff device appropriate for system.				
(4) Tested every three years.				
B. High level alarm				
(1) Present				
(2) Alarm is functional and operational.				
(3) Alarm is audible/visible to delivery driver.				
(4) Tested every three years.				
C. Ball float valves				
(1) Presence verified thru records and/or observation.				
(2) Ball float is operational.				
(3) Ball float is appropriate for system.				
(4) Tested every three years.				
III. OPERATION AND MAINTENANCE				
(1) Repairs to UST system performed according to a recommended practice.				
(2) Repaired UST system tightness tested within 30 days of repair.				
(3) CP system tested within 6 months of any CP repair.				
(4) Records of UST system repairs.				
(5) CP system properly operated and maintained to provide continuous protection.				
(6) CP system performing adequately based on results of testing, or CP system tested within 3 years and operator is conducting or completed repair.				
(7) Walkthrough inspections are conducted at least every 30 days. Facility must have records for the two most recent consecutive months, and for 10 of the last 12 months.				

Comments:

Facility ID: _____ AFIN: _____ Facility Name: _____

RELEASE PREVENTION (CONTINUED)

Check (✓) for compliance; “No” for noncompliance. Leave blank for “N/A”.

IV. CORROSION PROTECTION A. Material of Construction (Check all that apply)	System # _____		System # _____		System # _____		System # _____	
	Tank	Piping	Tank	Piping	Tank	Piping	Tank	Piping
NON-CORRODIBLE								
CORRODIBLE								
B. Internal lining								
(1) Installed according to a recommended practice.								
(2) Inspected in a timely manner and lining is in compliance.								
(3) Inspected according to approved protocol.								
(4) Corrective action taken on failed inspection.								
C. Galvanic (sacrificial) anodes								
(1) Designed by CP expert/specialist.								
(2) Tested in a timely manner.								
(3) Corrective action taken on failed test.								
(4) Metal components (i.e., flex lines, subpumps, etc.) protected as required.								
(5) Operational records available.								
D. Impressed current								
(1) Designed by CP expert/specialist.								
(2) Tested in a timely manner.								
(3) Rectifier is operational.								
(4) Verify records of 60 day check.								
(5) Corrective action taken on failed check.								
(6) Operational records available.								
(7) CP system maintained.								
(8) Metal components (i.e., flex lines, subpumps, etc.) protected as required.								
V. COMPATIBILITY All portions of the system are compatible with product stored.								

Comments:

RELEASE PREVENTION CHECKLIST: CORROSION PROTECTION

Date: _____

Please save your changes before proceeding.

Facility ID: _____ AFIN: _____ Facility Name: _____

AUTOMATIC TANK GAUGING

Manufacturer, name and model number of system: _____

Check (✓) for compliance; “No” for noncompliance. Leave blank for “N/A”.

(1) Device documentation is available at site (e.g., manufacturer's brochures, owners manual)?	
(2) Device can measure height of product to nearest one-eighth of an inch?	
(3) Documentation shows that water in bottom of tank is checked monthly to nearest one-eighth of an inch?	
(4) Documentation is available that the ATG was in test mode a minimum of once a month?	
(5) Checked for presence of gauge in tanks?	
(6) Checked for presence of monitoring box and evidence that device is working (i.e., device is equipped with roll of paper for results documentation)?	
(7) Owner/operator has documentation on file verifying method meets minimum performance standards of .20 gph with probability of detection of 95% and probability of false alarm of 5% for automatic tank gauging (e.g., results sheets under EPA's "Standard Test Procedures for Evaluating Leak Detection Methods")?	
(8) Verified documentation that system configuration, alarm and battery backup operability, probes, sensors, and floats were all inspected at least annually?	
(9) Maintenance records are available upon request?	
(10) Release detection system is operating properly (i.e., able to detect a release from any portion of the system that routinely contains product).	YES NO
(11) Tanks and piping are monitored monthly for releases and records are available (must have records for the two most recent consecutive months and for 10 months of the last 12 months).	YES NO

Comments:

AUTOMATIC TANK GAUGING CHECKLIST

Date: _____

Please save your changes before proceeding.

Facility ID: _____ AFIN: _____ Facility Name: _____

FINANCIAL ASSURANCE(1) Petroleum Storage Tank Trust Fund (PSTTF)? (check one) ☐ Yes ☐ No ☐ N/A(2) Can PSTTF deductible be satisfied? ☐ Yes ☐ No ☐ N/A

If No or N/A for PSTTF, mechanism for meeting financial responsibility? _____

Other SOC(1) Implementing agency has been notified of suspected release as required. ☐ Yes ☐ No ☐ N/A(2) Hazardous substance UST system release detection meets requirements (i.e., either secondarily contained or otherwise approved by the implementing agency). ☐ Yes ☐ No ☐ N/A(3) UST systems in temporary closure but still containing product, are compliant with release detection requirements (i.e., method present, operational, release investigated & reported as required). ☐ Yes ☐ No ☐ N/A**Operator Training/Certification Requirements**

Class A designated operator Name _____ # _____

☐ Yes ☐ No

Class B designated operator Name _____ # _____

☐ Yes ☐ No

Class C designated operator (minimum 1 operator per shift)

☐ Yes ☐ No ☐ *N/A

*Unmanned emergency generator facility (no class C required); OR

☐ Yes ☐ No

*Unmanned facility in compliance with Arkansas State Fire Code (no class C required);

☐ Yes ☐ No

If "NO", explain in comments

Training records maintained for all Class A, B, and C operators

☐ Yes ☐ No

Class A and Class B Operators certified within 30 days of assuming O/M responsibilities

☐ Yes ☐ No

Class A and Class B Operators recertified within 45 days of delivery prohibition violation

☐ Yes ☐ No ☐ *N/A

Class C Operator(s) training:

- Conducted by ADEQ-certified Class A or Class B operator

☐ Yes ☐ No

- Specific to facility

☐ Yes ☐ No

- Documented by ADEQ provided forms

☐ Yes ☐ No

- Adequately addresses delivery controls, monitoring of dispensing and emergency response

☐ Yes ☐ No

- Trained prior to assuming Class C responsibility

☐ Yes ☐ No**Comments:**

FINANCIAL ASSURANCE CHECKLIST

Date: _____

Please save your changes before proceeding.

INSPECTION SUMMARY**Check (✓) the appropriate box:**

Facility in compliance at time of inspection.

Facility non-compliant with Technical Compliance Rate.

Facility non-compliant with Financial Assurance requirements.

Facility has other non-TCR compliance issues.

I _____ certify that I have inspected the above named facility on _____.
(date/time)

Inspector's Signature:

IF DELIVERY PROHIBITION IS INVOKED, THE DESIGNATED CLASS A AND CLASS B OPERATOR MUST BE RECERTIFIED WITHIN 45 DAYS OF THE FACILITY BEING RED-TAGGED. IF FUEL DELIVERY PROHIBITION IS NOT IMMEDIATELY IMPLEMENTED. FAILURE TO CORRECT SOC NONCOMPLIANCE ISSUES IN THE TIMEFRAME GIVEN MAY RESULT IN FUEL DELIVERY PROHIBITION.

This inspection checklist and summary serve as your Notice of Noncompliance (if violations are indicated).

You have until _____ to provide evidence of compliance. Noncompliance issues could result in enforcement actions but not limited to, penalty assessments. Failure to resolve these noncompliance issues within the specified time frame could result in the escalation of enforcement action.



Name of Owner/Owner's Representative (Please Print) Signature of Owner/Owner's Representative Date

**INSPECTION SUMMARY
(CONTINUED)**

Comments:

SITE DIAGRAM

AST SITE DIAGRAM

Date: _____