



# ARKANSAS

## ENERGY & ENVIRONMENT

October 17, 2022

### Electronic Mail Only

Tom Huetter, P.G.  
Harbor Environmental and Safety  
5800 Evergreen Drive  
Little Rock, AR 72205  
[thuetter@harborenv.com](mailto:thuetter@harborenv.com)

**RE: NABORS Landfill, Three Brothers, AR  
Leachate System Repairs  
AFIN 03-00051, Permit No. 0249-S1-R2**

Dear Mr. Huetter,

The Division of Environmental Quality Office of Land Resources (DEQ) has reviewed the enclosed quote (AFT quote dated 10/06/2022 for \$10,361.34, estimate no. AFT24955) for leachate system repairs at Nabors Landfill. The quote is conditionally approved. Due to the potential overlapping of parts on estimate AFT24284 and AFT24955, only installed parts and related labor will be reimbursed following review of submitted invoices. At this time, please proceed with the leachate system repairs within the constraints of the approved quote and Contract # 4600037744.

Please provide DEQ with advance notice of the schedule for implementing the field work. If you have any questions, please contact Clay McDaniel at (501) 682-0836 or e-mail at [mcdaniel@adeq.state.ar.us](mailto:mcdaniel@adeq.state.ar.us).

Sincerely,

A handwritten signature in blue ink, appearing to read 'Dianna Kilburn'.

Dianna Kilburn, P.G.  
Operations Manager, Assessment and Remediation  
Office of Land Resources, Division of Environmental Quality  
5301 Northshore Drive, North Little Rock, AR 72118

Enclosure: AFT Quote for Leachate System Repairs dated 10/06/2022 (AFT24955)



# QUOTE

Advanced Fluid Technologies  
 7801 Warden Road  
 Sherwood, AR 72120

DATE	ESTIMATE NO.
10/6/2022	AFT24955

NAME / ADDRESS
Harbor Environmental Inc 5800 Evergreen Dr, Little Rock, AR 72205

Ship To
Harbor Environmental Inc 5800 Evergreen Dr, Little Rock, AR 72205

P.O. NO.	NOT VALID AFTER	REP	Project
	11/5/2022	MR	

ITEM	DESCRIPTION	QTY	U/M	COST	TOTAL
Group Invoice T...	Labor, Travel and Lodging				3,372.75T
611999	VLCS-2 Complete Simplex Control Panel, 1-Phase, 7 to 15 amps	1.00	ea	1,005.36	1,005.36T
611059	LCS-2 Logic Controller	1.00	ea	399.46	399.46T
611058	TM3 Analog Expansion Module - Single Input	1.00	ea	302.44	302.44T
611022	24 VDC transformer	1.00	ea	73.10	73.10T
301003	LCS-4 4" Submersible Pump Head, 25gpm, 304ss	1.00	ea	270.34	270.34T
341002	4" Submersible Motor, 1 hp 3 ph 230V	1.00	ea	669.56	669.56T
631052	100 Ft Pump Lead, 4/C #14 AWG w/Franklin Motor Plug (3 Wire)	1.00	ea	253.34	253.34T
611022	LCS-5 24 VDC transformer	1.00	ea	73.10	73.10T
611058	TM3 Analog Expansion Module - Single Input	1.00	ea	302.44	302.44T
611025	LCS-6 Altivar, VFD 3 HP, 230 v Single Phase to 230 v Three phase	1.00	ea	607.57	607.57T
611058	TM3 Analog Expansion Module - Single Input	1.00	ea	302.44	302.44T
301003	4" Submersible Pump Head, 25gpm, 304ss	1.00	ea	270.34	270.34T
341002	4" Submersible Motor, 1 hp 3 ph 230V	1.00	ea	669.56	669.56T
631052	100 Ft Pump Lead, 4/C #14 AWG w/Franklin Motor Plug (3 Wire)	1.00	ea	253.34	253.34T
611022	LCS-7 24 VDC transformer	1.00	ea	73.10	73.10T

**TOTAL**

Phone #	501-835-3200	orders@aftgrp.com
---------	--------------	-------------------



# QUOTE

Advanced Fluid Technologies  
 7801 Warden Road  
 Sherwood, AR 72120

DATE	ESTIMATE NO.
10/6/2022	AFT24955

NAME / ADDRESS
Harbor Environmental Inc 5800 Evergreen Dr, Little Rock, AR 72205

Ship To
Harbor Environmental Inc 5800 Evergreen Dr, Little Rock, AR 72205

P.O. NO.	NOT VALID AFTER	REP	Project
	11/5/2022	MR	

ITEM	DESCRIPTION	QTY	U/M	COST	TOTAL
611025	LCS-9 Altivar, VFD 3 HP, 230 v Single Phase to 230 v Three phase	1.00	ea	607.57	607.57T
	Do to the volatility of the world supply chain and pricing , this quote is ONLY GOOD FOR 30 DAYS.				
	Little Rock Sales Tax Group			9.00%	855.53

**TOTAL** \$10,361.34

Phone #	501-835-3200	orders@aftgrp.com
---------	--------------	-------------------