

ADEQ

ARKANSAS
Department of Environmental Quality

SEP 20 2017

William K. Honker, P.E.
Water Quality Protection Division (6WQ)
Environmental Protection Agency, Region 6
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733

RE: 2017 Water Quality Management Plan Governor Certification


Dear Director Honker:

Pursuant to the authority given to me by Governor Asa Hutchinson, I hereby certify that the Arkansas Water Quality Management Plan (WQMP) is current and has been updated as needed pursuant to Section 208 of the Clean Water Act and 40 CFR §130.6(e). These updates have been made available for public comment pursuant to 40 CFR §124.10. The WQMP is updated as needed as permits are issued, renewed, modified, or terminated. The current WQMP may be viewed at: <https://www.adeq.state.ar.us/downloads/water/NPDES/WQMP.xls>.

The previously submitted Arkansas Governor's certification was dated October 13, 2015, and was formally approved by EPA on April 13, 2016. The enclosed table lists all facilities that have had changes in the WQMP since the last certification, and these changes are indicated in the last column of the enclosed table.

If there are any questions, please contact Shane Byrum of my staff at (501) 682-0618 or byrum@adeq.state.ar.us.

Sincerely,


Becky W. Keogh
Director

Enclosure: September 2017 Governor Certification (Table 1)

cc: Syed A. Shahriyar, Regional Coordinator, WQMP Program, EPA Region 6
Shane Byrum, Engineer, Permits Branch, Office of Water Quality, ADEQ
Carrie McWilliams, P.E., Engineer Supervisor, Office of Water Quality, ADEQ
Bryan Leamons, P.E., Senior Operations Manager, Office of Water Quality, ADEQ
Bob Blanz, P.E., Ph.D., Chief Technical Officer, Office of Water Quality, ADEQ
Caleb Osborne, Associate Director, Office of Water Quality, ADEQ

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅ (Nov - Apr)	TSS (Nov - Apr)	NH ₃ -N (Nov - Mar)	NH ₃ -N (Apr)	DO (Nov - Apr)			TP (Nov - Apr)
AR0040266	145th St. Water & SID # 345	Cane Creek/Fish Creek	0.1	15	15	4	5.0		20	20	3	3	6.0		No record of formal approval. Technically accepted on 3/23/2006	
AR0052728	67 Pit Stop, LLC	Un Trib / Waggle Creek	0.002	10	15	10	2.0		10	15	13	6.1	5.0		New facility added to 208 Plan	
AR0044270	AHTD - Gurdon West Rest Area (Outfall 001)	Un Trib /Boggy Creek	0.0075	15	30	7	2.0		30 (BOD5)	30			5.0		CBOD5 limit revised for May-October	
AR0044270	AHTD - Gurdon West Rest Area (Outfall 002)	Un Trib /Boggy Creek	0.0075	15	30	7	2.0		30 (BOD5)	30			5.0		CBOD5 limit revised for May-October.	
AR0040827	Ar Dept Corr - Cummins	Canal No 19 / Cypress Creek	0.8	15	20	5	5.0		15	20	10	5.2	6.0		Receiving stream name corrected.	
AR0045888	Ark Dept Parks - Cane Creek State Park	Cane Creek Lake	0.0025	10	15	5	5.0	Report	10	15	10	6.1	5.0	Report	Facility design flow changed.	
AR0035947	Ark Dept Parks - Crowleys Ridge State Park	Un Trib /Ditch No 26	0.035	10	15	5	2.0		10	15	10	5.2	2.0		Receiving stream name corrected	
AR0037940	Ark Dept Parks - Devil's Den State Park	Un Trib /Lee Cr	0.04	10	15	5	5.0		10	15	10	5.3	6.0		DO limits were revised	
AR0052761	City of Arkadelphia - Sun Bio Project	Ouachita River	13.7	8569 lb/day (BOD5)	9940 lb/day (Jun-Oct)	457 lb/day (Jun-Oct)	2.0		8569 lb/day (BOD5)	16453 lb/day (Nov-May)	3393 lb/day (Nov-Feb)	1165 lb/day (Mar-May)	2.0		New facility added to 208 Plan	
AR0034550	Arkansas Steel Associates	Un Trib /Village Creek	0.270				2.0						5.0		Facility flow changed	
AR0050598	Huntington Estates Subdivision	Kaney Creek/E Fork Canev Creek	0.04	10	15	3	6.0	Report	10	15	6	5.6	2.0	Report	Facility design flow increased	
AR0035980	Arkansas Department of Corrections - Tucker Intermediate Reformatory	Wabaseka Bayou	0.5	10	15	5	5.0		10	15	14.7	5.2	5.0		Corrected name of receiving stream	
AR0041742	City of Ash Flat	North Big Creek	0.15	10	15	5	5.0	Report	10	15	8	7.8	5.0	Report	NH3-N limit for April revised	
AR0020702	City of Batesville (Outfall 001)	White River	4.4	Outfall 001 removed from WQMP										Outfall 001 removed from WQMP		
AR0022101	City of Beebe	Cypress Bayou	HCR	30 (BOD5)	90		5.0		Critical Limits apply year-round					FCB 12.5 Billion col/day (May-Oct) FCB 31.2 Billion col/day (Nov-Apr)	TMDL limits for FCB added	
AR0021792	City of Berryville	Mill Branch	2.4	10	15	1.6	6.0	1	10	15	4	1.6	6.0	1	TP 20.02 lb/day	TMDL limit for TP added and NH3 limit revised.
AR0022586	City of Blytheville - North	Un Trib /Ditch No 30	0.8	20	30	2	7.0		Critical Limits apply year-round						Facility flow correction from 0.08 to 0.8 mgd.	
AR0035955	Bryant School District - Salem Elementary School	Hurricane Lake	0.02	10	15	5.2	5.0		10	15	14.7	5.2	5.0		NH3-N and DO limits revised	
AR0052744	City of Buckner Municipal Waterworks	Un Trib /Bayou Dorcheat	0.7												Total Lead: 3.41 ug/L and 0.01991 lb/day	TMDL limit for Lead added
AR0044237	City of Burdette	Ditch # 24	0.06	Effluent Storage (April-November)					30 (BOD5) (Dec-Mar)	90				2.0		Facility flow decreased
AR0052485	City of Calion - South Addition	Calion Lake	0.01275	10	15	5	5.0	1	10	15	10	6.1	5.0	1	New facility added to 208 Plan	
AR0048275	Camp Ozark	Un Trib /Ouachita River	0.091	10	15	5	2.0		10	15	10	5.2	2.0		Design flow increased	
AR0052604	GenArk Investment Group, LLC - Rolling Creek Wastewater Treatment	Un Trib /Warren Cr	0.022	20	20	5	5.0		20	20	15	5.6	5.0		Facility name and permit number changed	
AR0021393	City of Cherry Valley	Cooper Creek	0.15	20	20	4	2.0		20	20	12	5.2	3.0		FCB: 5678 million col/day	Added TMDL limits for FCB
AR0051942	SamSand, LLC	Red River	0.1												Chloride: 250 mg/L TDS: 500 mg/L	Facility name change, added TMDL limits for TDS and Chlorides
AR0052809	Clampit LLC - Clampit Country Kitchen	Un Trib /Coleman Creek	0.00185	20	20	10	2.0		20	20	14	14	2.0		Add new facility and limits	
AR0037800	Clean Harbors El Dorado, LLC (Outfall 007)	Boggy Creek	HCR limit = 7% of upstream Q												Add facility to WQMP with flow limit at outfall 007	

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅	TSS	NH ₃ -N	DO	TP			
									(Nov - Apr)	(Nov - Apr)	(Nov - Mar)	(Apr.)	(Nov - Apr)			(Nov - Apr)
AR0043192	City of Colt	Taylor Creek Ditch	0.055	Effluent Storage May-Oct.					30 (BOD ₅)	90			2.0		FCB: 2082 million col/day	Add TMDL limit for FCB
AR0049247	City of Cove	Buffalo Creek	0.075	15	20	3	6.0		15	20	12	6.1	2.0			NH ₃ -N and DO limits revised
AR0042544	Speedy Stop, LLC	Un Trib /Fish Creek	0.003	15	20	5	3.0		20	20	12	6.1	2.0			Facility name change
AR0044041	Cross County High School	Cooper Creek	0.01	30 (BOD ₅)	30		3.0		30 (BOD ₅)	30			2.0	FCB: 75.71 million col/day (May-Sep) FCB: 378.5 million col/day (Oct-Apr)	Correct design flow and add TMDL limits for FCB	
AR0050563	Landers BCO, LLC d/b/a Crossroads Village	Un Trib /Clift Creek	0.05	15	20	5	3.0		15	20	10	6.1	4.0	TDS: 135.19 lb/day		Add TMDL limit for TDS, revise facility flow and DO limit for Nov-Apr.
AR0041432	City of Delight	Un Trib /Wolf Creek	0.12	20	30	3.7	3.0		25	30	10	6.1	5.0			CBOD ₅ , NH ₃ -N, and DO limits revised for May-Oct
AR0048615	Lake Catherine Waterworks & Sewer Facilities Board of Garland County - Riviera Utilities WWTF	Unnamed trib of Lake Catherine	0.05	10	15	5	5.0	Report	10	15	10	5.2	5.0	Report		Facility flow decreased.
AR0033987	City of Dumas	Canal 19/Bayou Macon	1.37	25 (Apr-Oct)	90	5.3	3.0		30 (BOD ₅) (Nov-Mar)	90		5.3	3.0			BOD ₅ replaced with CBOD ₅ for April NH ₃ -N limit added for April NH ₃ -N limit changed for May-Oct
AR0050717	Arkansas Water and Wastewater Management Corporation - Eaglebrook Subdivision	Un Trib /Little Palarm Cr	0.029	15	20	5	4.0		20	20	10	5.6	2.0			Facility flow increase.
AR0034304	City of Earle	Tyrnza River	0.59	30 (BOD ₅)	90		3.0		Critical Limits apply year-round						DO limit revised	
AR0049328	Saline County Property Owner's Improvement District #37 d/b/a Riverside Hills Subdivision Project	Un Trib /South Fork Saline River	0.035	10	15	5	6.0		10	15	10	5.2	6.0	TDS: 94.64 lb/day		TMDL limit for TDS added
AR0049743	City of El Dorado		This permit (AR0049743) was voided and limits transferred to AR0033743 and AR0033936											This permit removed from WQMP and limits transferred to AR0033723 and AR0033936		

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits					TMDL based limits	Changes Prompting Gov Cert			
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅	TSS	NH ₃ -N	NH ₃ -N	DO			TP		
									(Nov - Apr)	(Nov - Apr)	(Nov - Mar)	(Apr)	(Nov - Apr)			(Nov - Apr)		
AR0000752	El Dorado Chemical Company (Outfall 001)	Un Trib /Flat Creek	2.8		30	2.43	4.0										NH ₃ 37.9 lb/day (Apr-Oct) (Sum of Outfalls 001/003) NH ₃ 85.78 lb/day (Nov-Mar) (Sum of Outfalls 001/003) Chlorides 265 lb/day (Sum of Outfalls 001/003) Sulfates 503 lb/day (Sum of outfalls 001/003) TDS 1,338 lb/day (Sum of outfalls 001/003) Chlorides 19 mg/L (Outfall 001 and 003) Sulfates 41 mg/L (Outfall 001 and 003) TDS 138 mg/L (Outfall 001 and 003)	Added TMDL limits for Chlorides, Sulfates, TDS
AR0000752	El Dorado Chemical Company (Outfall 003)	Un Trib /Flat Creek	0.017	10	15	2.43	4.0		10	15	5.5	2.43	2.0				NH ₃ 37.9 lb/day (Apr-Oct) (Sum of Outfalls 001/003) NH ₃ 85.78 lb/day (Nov-Mar) (Sum of Outfalls 001/003) Chlorides: 265 lb/day (Sum of Outfalls 001/003) Sulfates 503 lb/day (Sum of outfalls 001/003) TDS 1,338 lb/day (Sum of outfalls 001/003) Chlorides 19 mg/L (Outfall 001 and 003) Sulfates 41 mg/L (Outfall 001 and 003) TDS 138 mg/L (Outfall 001 and 003)	Added TMDL limits for Chlorides, Sulfates, TDS
AR0000752	El Dorado Chemical Company (Outfall 002)	Un Trib /Flat Creek	Variable														Chlorides 73 lb/day (Sum of outfalls 002,006,007) Sulfates 33 lb/day (Sum of outfalls 002,006,007) TDS 635 lb/day (Sum of outfalls 002,006,007)	Added TMDL limits for Chlorides, Sulfates, TDS
AR0000752	El Dorado Chemical Company (Outfall 006)	Un Trib /Flat Creek	Variable														Chlorides 73 lb/day (Sum of outfalls 002,006,007) Sulfates 33 lb/day (Sum of outfalls 002,006,007) TDS 635 lb/day (Sum of outfalls 002,006,007)	Added TMDL limits for Chlorides, Sulfates, TDS
AR0000752	El Dorado Chemical Company (Outfall 007)	Un Trib /Flat Creek	Variable														Chlorides 73 lb/day (Sum of outfalls 002,006,007) Sulfates 33 lb/day (Sum of outfalls 002,006,007) TDS 635 lb/day (Sum of outfalls 002,006,007)	Added TMDL limits for Chlorides, Sulfates, TDS

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ N	DO	TP	CBOD ₅	TSS	NH ₃ N	DO	TP			
																(Nov. - Apr.)
AR0033936	El Dorado Water Utilities-North (Outfall 001)	Un Trib /Flat Creek	5	10	15	Short term (<5 days) (May) T<26C: 7.5 26-28C: 7.2 >28C: 6.3 June-Oct: 6.1	5.0			10	15	Short term (<5 days) (Nov-Mar): 13.5 Short term (<5 days) (Apr): 11.7 18.1-20C: 13.3 20.1-22C: 10.3 22.1-24C: 9.1 24.1-26C: 7.95 26.1-28C: 7.0 >28C: 6.2	8.0			Transfer Outfall 001 limits from AR0049743 to AR0033936 and remove AR0049743 from 208 plan.
AR0033936	El Dorado Water Utilities-North (Outfall 001)	Un Trib /Flat Creek	5	10	15	Long term (>5 days) May T<18C: 5.0 18.1-20C: 4.79 20.1-22C: 4.21 22.1-24C: 3.70 24.1-26C: 3.25 26.1-28C: 2.86 >28C: 2.51 June-Oct: 2.4	5.0		10	15	Long term (>5 days) (Nov-Mar): 6.8 Long term (>5 days) (Apr): 5.33 18.1-20C: 4.68 20.1-22C: 4.12 22.1-24C: 3.62 24.1-26C: 3.18 26.1-28C: 2.80 >28C: 2.46	8.0			Transfer Outfall 001 limits from AR0049743 to AR0033936 and remove AR0049743 from 208 plan.	
AR0033936	El Dorado Water Utilities-North (Outfall 010N)	Ouachita River (via joint pipeline)	5	22.5	30	354.4 lb/day			25	30	1146.7 lb/day	1146.7 lb/day			Transfer Outfall 010N limits from AR0049743 to AR0033936.	

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ N	DO	TP	CBOD ₅ (Nov. - Apr.)	TSS (Nov. - Apr.)	NH ₃ N (Nov. - Mar.)	DO (Nov. - Apr.)	TP (Nov. - Apr.)			
AR0033723	El Dorado Water Utilities- South (Outfall 001)	Bayou De Loutre	7	10	15	Short term (<5 days) May T<26C: 7.5 26-28C: 7.08 >28C: 6.23 Jun-Oct 6.1	3.0			25	30	Short term (<5 days) T<20C: 10.2 20-22C: 9.73 22.1-24C: 8.55 24.1-26C: 7.5 26.1-28C: 6.6 >28C: 5.8	5.0			Transfer Outfall 001 limits from AR0049743 to AR0033723 and remove AR0049743 from 208 plan.
AR0033723	El Dorado Water Utilities- South (Outfall 001)	Bayou De Loutre	7	10	15	Long term (>5 days) May T<18C 5.0 18.1-20C 4.74 20.1-22C: 4.17 22.1-24C 3.66 24.1-26C 3.22 26.1-28C 2.83 >28C: 2.49 June-Oct 2.4	3.0		25	30	Long term (>5 days) April T<18C: 5.03 18.1-20C: 4.42 20.1-22C: 3.89 22.1-24C: 3.42 24.1-26C: 3.60 26.1-28C 2.64 >28C 2.32	5.0			Transfer Outfall 001 limits from AR0049743 to AR0033723 and remove AR0049743 from 208 plan	
AR0033723	El Dorado Water Utilities-South (Outfall 010S)	Ouachita River (via joint pipeline)	7	22.5	30	496.3 lb/day			25	30	1605.5 lb/day	1605.5 lb/day				Outfall 010S limits transferred from AR0049743 to AR0033723

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits						TMDL based limits	Changes Prompting Gov Cert
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅	TSS	NH ₃ -N	DO	TP			
									(Nov - Apr)	(Nov - Apr)	(Nov - Mar)	(Apr.)	(Nov - Apr)	(Nov - Apr.)		
AR0022420	City of Elaine	Govan Slough	0.1	Effluent Storage May-Oct					25	90	8	8	5.0		April NH3 limit was corrected	
AR0039594	City of Emerson	UnTrib/Little Cypress Creek	0.05	15	30	6	3.0		20 (BOD5)	30			3.0		CBOD5 limit for May-Oct changed	
AR0000523	Evrax Stratcor (Outfall 001)	Lake Catherine	HCR limit of 0.5% riverflow and 2.6 mgd max			100					100	100			Facility added to 208 Plan with HCR flow limits	
AR0023817	City of Foreman	East Flat Creek	0.28	15	15	6	3.0		20	20	12	6.1	4.0		DO limit for Nov-Apr revised	
AR0050750	HSNC, LLC d/b/a Village Springs Health and Rehabilitation	S Fork Saline River	0.02	10	15	5	3.0	Report	10	15	10	8	5.0	Report	NH3 limit for April revised, facility name change	
AR0036668	Frit Industries, Inc	Un Trib / Coon Creek	HCR*	*Effluent flow is HCR limited to 15% of downstream flow (Jul-Sep) and 0.6 MGD maximum (Dec-May)											HCR flow limits were added	
AR0001601	Mondi Bags USA, LLC and Mondl Pine Bluff, LLC (Outfall SUM)	Arkansas River	6.22	BOD5 2850 lb/day					Critical Limits apply year-round							Facility name change
AR0048097	Georgia Pacific Crossett LLC - North Log Yard	Un Trib./Little Brushy Creek	1.5	40 (BOD5)	35		2.0		40 (BOD5)	35			5.0		Added TSS and DO limits	
AR0021679	City of Gould	Un Trib /Kerch Canal	0.15	20	30	5	4.0		20	30	10	5.2	2.0		Ammonia limit for April and DO limit for Nov-Apr were revised	
AR0052337	Jim Swinford d/b/a Grace Manor Apartments	Un Trib/Spring River	0.006	10	15	5	4.0		10	15	10.3	3.9	4.0		New facility added to WQMP	
AR0022454	City of Greenwood	Un Trib / Vache Grasse Creek OR Holding pond on Vache Grasse Country Club golf course	1.8	15	20	2.2	4.0		15	20	4	2.2	7.5		Added alternative receiving stream	
AR0039781	Hackett	Big Branch of Hackett Creek	0.081	20	20	4	4.0		30 (BOD5)	45			2.0		Limit changes for CBOD5, TSS, NH3-N, DO	
AR0052345	Halliburton Energy Services, Inc - Magnet Cove Plant	Un Trib/Reyburn Creek	0.0021	10	15	10	3.0		10	15	14.7	5.2	3.0		New facility added	
AR0033863	City of Harrisburg	Town Creek	0.403	20	20	4	4 (Jun-Oct)		20	30	6	5.2	5 (Nov-May)	FCB (year-round) 15260 million col/day	TMDL limit for FCB added	
AR0043389	City of Helena	Mississippi River	1.7	30 (BOD5)	90		2.0		Critical Limits apply year-round							DO limit added.
AR0044822	City of Higginson	Gurn Springs Creek	0.1435	20	20	4	4.0		20	20	12	5.6	4.0		NH3-N limit for April corrected	
AR0037249	Holiday Island SID	Table Rock Lake (in Missouri)	0.5	10	15	3.9	5.0	2.1 lb/day	10	15	5	3.9	5.0	2.1 lb/day	TP mass limits added per Missouri CSR and previous permit	
AR0037435	Holiday Shores Resort	Bull Shoals Lake	0.0033	10	15	3.9	6.0		10	15	10	3.9	6.0		DO limit revised	
AR0049051	Humane Society of Pulaski Co	Un trib /McHenry Creek	0.004	15	20	5	3.0		15	20	12	6.1	2.0		NH3-N limit for April was revised	
AR0001970	Evergreen Packaging, Inc - Pine Bluff Mill	Arkansas River	41	25528 lb/day (BOD5)					Year-round						WQBEL for BOD5 replaced with more stringent TBEL	
AR0043401	Jonesboro-Eastside WWTP	Whiteman Creek	9	20	30	2.1	5.0		20	30	4	2.1	7.0		NH3-N limit revised for Nov-Mar	
AR0047732	Interfor U S Inc (Outfalls 001 and 002)	Un Trib /Clear Creek	Variable	50 (BOD5 daily max)	35 (daily max)		2.0		Critical Limits apply year-round							Facility name change
AR0035742	City of Judsonia	Little Red River	0.2	30 (BOD5)	90		2.0		Critical Limits apply year-round						FCB 3030 million col/day (Apr-Sep) FCB 15100 million col/day (Oct-Mar)	TMDL limits for FCB added

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅	TSS	NH ₃ -N	NH ₃ -N	DO			TP
AR0038121	Lake Catherine State Park	Lake Catherine	0.03	10	15		5.0	12.2	Critical Limits apply year-round						TP limit added and BOD ₅ changed to CBOD ₅ .	
AR0036811	Lake Ouachita State Park	Lake Ouachita	0.05	10	15	5	5.0	1.0	10	15	10	5	5.0	1		TP limit added
AR0041327	City of Lake View	Johnson Bayou	0.076	20	30	5	3.0		20	30	12	5.2	2.0			NH ₃ -N limit for April corrected
AR0040177	Little Rock Wastewater Utility - Fourche Creek WWTP	Arkansas River	16	30 (BOD ₅)	30		2.0		Critical Limits apply year-round					TRC: 1.5 mg/l (Inst. Max) from WQ study, not TMDL based.	Removed NH ₃ -N limits during May-October Replaced CBOD ₅ limits with BOD ₅ limits during May-October.	
AR0046418	Bonanza Creek Energy Resources, LLC - McKamie Gas Plant	Un Trib /Crooked Creek	Variable	10 (BOD ₅)	35		2.0		10 (BOD ₅)	35			5.0			Facility name change, BOD ₅ limit change, DO limit added
AR0052680	Love's Travel Stops & Country Stores, Inc dba Love's Travel Center - Pine Bluff	Cousart Bayou	0.01	15	20	5.2	4.0		15	20	12	12	4.0			New facility added to WQMP
AR0052736	Magnolia Utilities - Sterling Lacy WTR Purification	Un Trib /Big Creek	0.136												Total Lead 2.67 ug/L and 0.0031 lb/day	Facility and TMDL limit for Lead added
AR0048399	Maple Creek Farms Tract C H	Un trib /Ferguson Lake	0.0006	20	20	5	3.0		20	20	12	6.1	2.0			Receiving stream name corrected
AR0034142	City of Marianna - Pond B	L'Anguille River	0.4	30 (BOD ₅)	90		4.0		30 (BOD ₅)	90			2.0			Added minimum upstream flow for permitted discharge
AR0034169	City of Marianna - Pond A	L'Anguille River	0.6	30 (BOD ₅)	90		4.0		30 (BOD ₅)	90			2.0			Added minimum upstream flow for permitted discharge
AR0021971	City of Marion (Outfall 002)	Mississippi River	4.5 (daily max)	30 (BOD ₅)	90		2.0		30 (BOD ₅)	90			2.0			Daily max flow limit of 4.5 MGD added
AR0049301	New Neptune, LLC - Max Mart #1026	Un Trib /Little Cypress Creek	0.0015	20	20	5	3.0		20	20	12	12	2.0			NH ₃ -N limit revised for April
AR0036692	City of Mena	Un trib /Prairie Creek	3.1	10	15	3 (May) 2.1 (Jun-Oct)	7.1		10	15	5.9	4.9	7.1			NH ₃ -N limits revised for April and May
AR0037079	Millwood State Park	Un Trib/Buster Creek	0.02	10	15	6	2.0		10	15	12	6.1	4.0			DO limit for Nov-Apr changed
AR0033651	City of Monette	Little Ditch #3	0.35	15	15	4	5.0		15	15	11	5.2	5.0			Design flow increase
AR0046141	Mountain Valley Retreat Center	Un Trib/S Fork Saline River	0.025	10	15	5	2.0		10	15	10	5.2	2.0		TDS 67.6 lb/day	TMDL limit added
AR0052574	RET Development, LLC - Mountain Valley Subdivision	Nowlin Creek	0.04	10	15	4	6.0		20	20	14.7	5.2	2.0			New facility added to 208 Plan
AR0037044	City of Newport	Un trib/Village Creek	1.6	10	15	3	6.0		10	15	8.43 (Nov) 12 (Dec-Mar)	12	5.0			NH ₃ limit change for May-Oct and Nov
AR0045225	Newport-Airport Ind Park	Un Trib./Locust Creek	0.5	20	20	8	5.0	Report	20	20	8	6.2	6.0	Report		CBOD ₅ , NH ₃ -N, TSS limits revised
AR0048194	Jessieville Public School District / Fountain Lake Public School District	Un Trib /Coleman Creek	0.01	10	15	5	2.0		15	20	10	5.2	2.0		TDS 27.04 lb/day	Facility name changed and TMDL limit for TDS added
AR0038288	North Little Rock Wastewater Utility - White Oak Bayou	Arkansas River	8.5	30 (BOD ₅)	90		2.0	Report	Critical Limits apply year-round						Added TRC limit of 1.1 mg/l (inst. Max) from site specific study	
AR0035688	City of Ola	Keeland Creek	0.15	20	20	5	4.0		20	20	12	5.6	2.0			April NH ₃ limit and receiving stream corrected
AR0050458	Refugio Reyes dba El Acapulco Restaurant	Un Trib /Glazypeau Creek	0.002	15	20	5	3.0		20	20	12	5.2	2.0			Facility name change

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits						TMDL based limits	Changes Prompting Gov Cert
				CBOD ₅	TSS	NH ₃ N	DO	TP	CBOD ₅	TSS	NH ₃ N	DO	TP			
									(Nov - Apr)	(Nov - Apr)	(Nov - Mar)	(Apr)	(Nov - Apr.)	(Nov - Apr)		
AR0039233	City of Pangburn	Little Red River	0.2	30 (BOD ₅)	30		2.0		Year-round						FCB 3030 million col/day (May-Sep) FCB 15100 million col/day (Oct-Apr)	Added TMDL limits for FCB
AR0052451	Peco Foods, Inc	Black River	1.66	16 (BOD ₅)	20	4	2.0	Report	Critical Limits apply year-round							New facility added to 208 Plan
AR0052647	Leonard Stephenson dba Pine Haven Park	Un trib./Godfrey Creek	0.0075	20	20	5	3.0		20	20	12	6.1	2.0		Permit number and facility name changed.	
AR0050423	Maple Ridge Village	Un trib./Copperas Creek	0.011	15	20	5	5.0		20	20	10	5.2	5.0		Facility name change.	
AR0050571	Faulkner County Public Facility Board - dba Preston Community Wastewater Utility	Lake Conway	0.154	10	15	5	5.0	1	Critical Limits apply year-round							Total Phosphorus limit added
AR0050512	Reynolds Consumer Products, LLC - Hot Spring Continuous Rolling Mill	Stony Creek	Variable (Modeled at 0.5 mgd)	40 (BOD ₅)	35		3.5		40 (BOD ₅)	35			6.5		Facility name changed	
AR0052663	City of Rockport	Un Trib /Francois Creek	0.0455	10	15	7	3.0		10	15	7	6.1	6.0		New facility added to WQMP	
AR0045373	City of Rondo	Un Trib /Big Cypress Creek	0.05	Effluent Storage May-Oct					25	90	15	15	5.0		Facility flow and NH ₃ limits corrected	
AR0022217	Russell	Glause Creek	0.03	20	20	5	5.0		20	20	13	5.2	2.0		Correction of receiving stream	
AR0052698	SHM Brady Mountain, LLC - Brady Mountain Marina Resort WWTP	Un Trib/Lake Ouachita	0.02	10	15	5.2	6.0	1	10	15	14.7	5.2	6.0	1	New facility added to WQMP	
AR0043753	Sugarloaf Waste Water Treatment	East Sugarloaf Creek arm of Bull Shoals Lake	0.362	10	15	3.9	5.0	1	10	15	5	3.9	5.0	1	Facility name updated	
AR0044695	Hanumanta, LLC - Relax Inn	Shell Lake	0.012	10	15	5	5.0	Report	10	15	10	5.2	5.0	Report	Facility name change	
AR0049581	Family Church, Inc - The Family Church	Un Trib/Arnold Creek	0.0031	15	20	5	2.0		20	20	10	6.1	2.0		NH ₃ -N limit for April corrected	
AR0021954	City of Turrell	Big Creek	HCR limit of 23% of upstream flow	30 (BOD ₅)	90		3.0		Critical Limits apply year-round							HCR flow limit added
AR0050547	Two Rivers Harbor Property Owners Association, Inc	Arkansas River	0.002	30 (BOD ₅)	30		2.0		Critical Limits apply year-round							Facility name changed
AR0039268	Tyson Foods - Clarksville	Un Trib (a.k.a. Blue Creek)	1.65	10	15	5	5.0		10	15	6	5.6	5.0		Receiving stream name corrected	
AR0042455	Tyson Poultry, Inc - River Valley Animal Foods	Arkansas River	0.82	50	60	38	3.0		Critical Limits apply year-round							Revised flow and TSS limit
AR0049352	USDA Aquaculture Research Service	Un Trib/Little Lagrue Bayou	0.14	10	15	5.2	3.0		10	15	7	5.2	5.0		NH ₃ -N and DO limits changed	
AR0020648	USDAFS Cass Civilian Conservation Center	Fane Creek	0.033	10	15	5	6.0		10	15	5	5	5.0		Receiving stream changed due to outfall move	
AR0052671	US National Parks Service - Arkansas Post National Memorial	Un Trib/Little Post Bayou	0.0021	10	15	5	4.0		10	15	5	5	5.0		New facility added to 208 Plan	
AR0049409	Vandale-Birdseye Water Association, Inc.	L'Anguille River	0.05	Effluent Storage May-October					30 (BOD ₅)	90			2.0		Facility name updated	

Table 1
Arkansas Department of Environmental Quality
WQMP Governor Certification
September 2017

NPDES#	Facility Name	Receiving Stream	Facility flow (MGD)	Critical Limits (May-Oct.)					Seasonal Limits					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅	TSS	NH ₃ -N	NH ₃ -N	DO			TP
									(Nov - Apr.)	(Nov - Apr.)	(Nov - Mar)	(Apr)	(Nov - Apr)			(Nov - Apr.)
AR0036544	Viskase Companies, Inc.	Mississippi River	1.371	800 lb/day		1300 lb/day	2.0									Facility flow revised
AR0039896	City of Wabbaseka	Lateral No 2/Bradley Slough	0.1	15	20	3	5.0		15	20	10	5.2	5.0			Receiving stream name and NH3 limit for April were corrected.
AR0043508	City of Waldo	Un Trib./Big Creek	0.35	20	20	5	4.0		20	20	10	6.1	4.0		Total Lead: 0.0079 lb/day and 2.67 ug/L	Concentration limit for Lead of 2.67 ug/L was added from TMDL
AR0035769	City of Waldron	Unnamed trib/Poteau River	0.85	15	15	5	5.0	1	15	15	8	5.6	6.0	1	Total Copper: 0.065 lb/day and 9.2 ug/l Total Zinc: 0.606 lb/day and 85.5 ug/l Total Phosphorus: 7.09 lb/day and 1.0 mg/l	TMDL limits added for Phosphorus, Zinc and Copper
AR0046566	City of Walnut Ridge	Village Creek	1.19	10	15	4	5.0	Report	10	15	6	6	6.0	Report		No record of formal approval Tech Acceptance on 11/10/1992
AR0047554	Ward	Four Mile Creek	0.5	10	15	5	3.0		10	15	10	5.2	5.0		FCB: 7580 million col/day (Apr-Sep) FCB: 19000 million col/day (Oct-Mar)	TMDL limits added for FCB
AR0050393	WVE POA - Waterview Estates WWTP	Mill Bayou/Arkansas River	0.02	15	20	5	3.0		20	20	10	5.6	2.0			NH3-N limit for April was revised
AR0045403	TA Operating, LLC - Earle Travel Center	Un. Trib./Ditch No. 22	0.03	20	20	5	3.0		20	20	12	5.2	2.0			Facility name changed
AR0043940	West Side School District #4	Un Trib./Greens Ferry Lake	0.014	10	15	5	2.0		10	15	10	5.3	2.0			Facility name changed.
AR0002917	Weyerhaeuser-Dierks (Outfall 002)	Holly Creek	0.183 (May-Oct) 0.349 (Nov-Apr)	15 (BOD5)	35		3.0		21 (BOD5)	35			3.0		Sum Total Load Limit for Outfalls 002, 003, 007: E. Coli: 86,500 million col/day (Oct-Mar) E. Coli: 17,300 million col/day (Apr-Sep)	TMDL limits for E. Coli added
AR0002917	Weyerhaeuser-Dierks (Outfall 003)	Holly Creek	0.165 (May-Oct) 0.291 (Nov-Apr)	15 (BOD5)	35		3.0		21 (BOD5)	35			3.0		Sum Total Load Limit for Outfalls 002, 003, 007: E. Coli: 86,500 million col/day (Oct-Mar) E. Coli: 17,300 million col/day (Apr-Sep)	TMDL limits for E. Coli added
AR0002917	Weyerhaeuser-Dierks (Outfall 004)	Holly Creek	2-23 cfs maximum when Holly Creek is ≥10 cfs and <100 cfs 11 cfs maximum when Holly Creek ≥100 cfs	Report (COD)	Report				Report (COD)	Report					Sum Total Load Limit for Outfalls 002, 003, 007: E. Coli: 86,500 million col/day (Oct-Mar) E. Coli: 17,300 million col/day (Apr-Sep)	TMDL limits for E. Coli and HCR flow limits added
AR0052621	Waste Water Management, Inc - Woodland Edge Subdivision	Un trib./Little Creek	0.03	15	20	8	3.0	Report	15	20	15	10	3.0	Report		New facility added to 208 Plan
AR0050156	Gilani El Paso Properties LLC - El Paso Exxon Food Mart	Un Trib./Little Cypress Creek	0.005	20	20	5	2.0		20	20	12	12	2.0			CBOD5, NH3-N, DO limits revised