



ARKANSAS  
Department of Environmental Quality

June 1, 2012

Mr. Bill Horton  
Halliburton Energy Services  
2000 Darby Lane  
Malvern, AR 72104

RE: NPDES Permit Number AR0049794, AFIN 30-00348  
DMR Effluent Violations

Dear Mr. Horton:

A recent review of the NPDES file for the Halliburton Energy Services has revealed the following violations for the monitoring period ending April 30, 2012.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	Beryllium, total recoverable (MO AVG)	0.19	0.08	ug/L
001-A	Beryllium, total recoverable (DAILY MX)	0.3	0.24	ug/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number AR0049794 and AFIN 30-00348 in any written correspondence to ADEQ. Should you have any questions, feel free to contact me at 501-682-0632 or e-mail at [bolenbaugh@adeq.state.ar.us](mailto:bolenbaugh@adeq.state.ar.us).

Thank you,

Jason R. Bolenbaugh  
Enforcement Analyst  
Water Division Enforcement Branch