

ANNUAL AUTOMATIC TANK
GAUGE OPERATION INSPECTION

t: 501-682-0744 | alt. t: 501-682-0856 | f: 501-682-0880 | e: RSTComplianceForms@adeq.state.ar.us

SECTION 1: FACILITY INFORMATION		SECTION 2: OWNER INFORMATION	
Facility Name:		Owner's Name:	
Street Address:		Street Address:	
City:		City:	
State:	Zip Code:	State:	Zip Code:
Facility ID#:		Phone #:	
Testing Company:		Alt. Phone #:	Date:
SECTION 3: STORAGE TANK INFORMATION			
This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.			
Tank Number:			
Product Stored:			
ATG Brand and Model:			
1. Tank Volume, Gallons:			
2. Tank Diameter, Inches:			
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	Yes No	Yes No	Yes No
4. Float moves freely on the stem without binding?	Yes No	Yes No	Yes No
5. Fuel float level agrees with the value programmed into the console?	Yes No	Yes No	Yes No
6. Water float level agrees with the value programmed into the console?	Yes No	Yes No	Yes No
7. Inch level from bottom of stem when 90% alarm is triggered.			
8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge?	Yes No	Yes No	Yes No
9. Inch level from the bottom when the water float first triggers an alarm.			
10. Inch level at which the water float alarm activates corresponds with value programmed in the gauge?	Yes No	Yes No	Yes No
If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.			
Test Results:	Pass Fail	Pass Fail	Pass Fail

Comments:

Tester's Name:

Tester's Signature:

Tester's License #:

License Exp. Date: