



ANNUAL LIQUID SENSOR INSPECTION

t: 501-682-0744 | alt. t: 501-682-0856 | f: 501-682-0880 | e: RSTComplianceForms@adeq.state.ar.us

SECTION 1: FACILITY INFORMATION			SECTION 2: OWNER INFORMATION			
Facility Name:			Owner's Name:			
Street Address:			Street Address:			
City:			City:			
State:		Zip Code:	State:		Zip Code:	
Facility ID#:			Phone #:			
Testing Company:			Alt. Phone #:		Date:	
SECTION 3: LIQUID SENSOR DATA						
This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RP1200 Section 8.3 for the test procedure.						
Sensor Location						
Product Stored						
Type of Sensor	Discriminating Non-discriminating	Discriminating Non-discriminating	Discriminating Non-discriminating	Discriminating Non-discriminating	Discriminating Non-discriminating	Discriminating Non-discriminating
Test Liquid	Water Product	Water Product	Water Product	Water Product	Water Product	Water Product
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
Is the sensor alarm circuit operational?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
Has sensor been inspected and in good operating condition?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
When placed in the test liquid, does the sensor trigger an alarm?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
When an alarm is triggered, is the sensor properly identified on the ATG console?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No

SECTION 3: LIQUID SENSOR DATA

Any "No" answers indicates the sensor fails the test.

Test Results	Pass	Fail	Pass	Fail	Pass	Fail	Pass	Fail	Pass	Fail	Pass	Fail
--------------	------	------	------	------	------	------	------	------	------	------	------	------

Comments:

Tester's Name:			
Tester's Signature:		Tester's License #:	
		License Exp. Date:	