



3-YEAR OVERFILL EQUIPMENT INSPECTION

t: 501-682-0744 | alt. t: 501-682-0856 | f: 501-682-0880 | e: RSTComplianceForms@adeq.state.ar.us

SECTION 1: FACILITY INFORMATION				SECTION 2: OWNER INFORMATION		
Facility Name:				Owner's Name:		
Street Address:				Street Address:		
City:				City:		
State:		Zip Code:		State:		Zip Code:
Facility ID#:				Phone #:		
Testing Company:				Alt. Phone #:		Date:
SECTION 3: AUTOMATIC SHUTOFF DEVICES DATA						
This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.						
Product Grade:						
Tank Number:						
Tank Volume, gallons:						
Tank Diameter, inches:						
Overfill Prevention Device Brand:						
Type:	Automatic Shutoff Device Ball Float Valve	Automatic Shutoff Device Ball Float Valve	Automatic Shutoff Device Ball Float Valve	Automatic Shutoff Device Ball Float Valve	Automatic Shutoff Device Ball Float Valve	Automatic Shutoff Device Ball Float Valve
Automatic Shutoff Device Inspection						
1. Drop tube removed from tank?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
2. Drop tube and float mechanisms free of debris?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
3. Float moves freely without binding and poppet moves into flow path?	Yes No Not Present	Yes No Not Present	Yes No Not Present	Yes No Not Present	Yes No Not Present	Yes No Not Present
4. Bypass valve in the drop tube open and free of blockage (if present)?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
5. Flapper adjusted to shut off flow at 95% capacity? ¹	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
A "No" to any item in lines 1-5 indicates a test failure.						

SECTION 3: AUTOMATIC SHUTOFF DEVICES DATA

Ball Float Valve Inspection²

1. Tank top fittings vapor tight and leak-free?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
2. Ball float cage free of debris?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
3. Ball free of holes and cracks and moves freely in cage?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
4. Vent hole in pipe open and near top of tank?	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
5. Ball float pipe proper length to restrict flow at 90% capacity? ³	Yes No	Yes No	Yes No	Yes No	Yes No	Yes No
A "No" to any item in lines 1-5 indicates a test failure.						
Test Results	Pass	Fail	Pass	Fail	Pass	Fail

1. Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.
2. If a ball float is found to fail the inspection, another method of overfill must be used.
3. Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

Comments:

Tester's Name:

Tester's Signature:

Tester's License #:

License Exp. Date: