



ENVIRONMENTAL
QUALITY

SPILL BUCKET TESTING FLOW CHART

FAILED SPILL BUCKET TEST

Owner/Operator
required to report
to DEQ within
24 hours

Generate a
suspected LUST

Owner/Operator
has 7 days to
confirm or deny
a release

Owner/
Operator
denies a
release to the
environment

Owner/Operator
confirms a release
into the environment

Confirm LUST and
send to technical for
further action

Owner/Operator
has 30 days to
repair/replace and
retest spill bucket

If no evidence
of attempted
compliance,
the tank
will be
RED TAGGED

Keep test results
for 3 years

Passed Spill
Bucket Test

