

UNDERGROUND STORAGE TANK PUBLIC RECORD

Public Record Posted Date: December 14, 2020

Information contained in this record is based on a universe of regulated underground storage tanks (USTs) as defined by 40 CFR 280 and APC&EC Regulation No.12

General Information

Total number of Underground Storage Tanks Facilities as of report date: 3,023

Total number of Underground Storage Tanks as of report date: 7,625

Information For Compliance Inspections

Number of Underground Storage Tank Facilities Inspected: 1,281

Inspection Period Dates: 10/01/2019 to 09/30/2020

Percent Compliance (Release Prevention and Release Detection): 57%

Note: Compliance rate is based on the combined performance measures indicated for significant operational compliance with state and Federal UST requirements.

Information For Release

Number of Confirmed Releases: 23

Release Reporting Period Dates 10/01/2019 to 09/30/2020

Information For Release Sources and Causes From Underground Storage Tanks

Source/Location			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problems		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	4	17.30	0	0.00	1	25.00	0	0.00	1	25.00	0	0.00	0	0.00	2	50.00
Piping	3	13.00	0	0.00	0	0.00	2	66.60	0	0.00	0	0.00	1	33.30	0	0.00
Dispenser	0	0.00	0	100.00	0	100.00	0	100.00	0	100.00	0	100.00	0	100.00	0	100.00
STP	6	26.00	0	0.00	0	0.00	5	83.30	0	0.00	0	0.00	1	16.60	0	0.00
Delivery Problem	0	0.00	0	100.00	0	100.00	0	100.00	0	100.00	0	100.00	0	100.00	0	100.00
Other	1	4.30	0	0.00	0	0.00	1	100.00	0	0.00	0	0.00	0	0.00	0	0.00
Unknown	9	39.10	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	9	100.00
Totals	23		0	0.00	1	4.30	8	34.70	1	4.30	0	0.00	2	8.70	11	47.80

Note: "Unknown" is based on an unidentifiable source or cause of release.

"Other" is an identifiable source or cause of release that does not fit specific locations identified in the chart.

For site-specific information, visit ADEQ's Regulated Storage Tanks Division online database at www.adeq.state.ar.us/rst/programs/fees/database.aspx.