## **Underground Storage Tanks (USTs) Public Record**

General Information  Total Number Of Active UST Facilities: 2955  Total Number Of Active USTs: 7397	Public Record Posted Date:	
Summary Information For On-Site Inspection Number Of UST Facilities Inspected: 1249	ıs	

Inspection Period Dates: 10/1/24 To: 9 / 3 0 / 2 5
Percent Compliance (Technical Compliance Rate Measure): 57.24

Note: Compliance rate is based on the combined performance measures indicated for technical compliance rate with state and Federal UST requirements.

## **Summary Information For Release**

Number Of Confirmed UST Releases: 33

Release Reporting Period Dates: 10/1/24 to 9/30/25

**Summary Information For Release Sources And Causes** 

			Cause													
Source		Spill Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown				
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	5	15	0		0		2	40	0		0		0	0	3	60
Piping	9	27	0		0		3	33	0		0		3	33	3	33
Dispenser	1	3	0		0		1	100	0		0		0	0	0	0
STP	3	9	0		0		2	67	0		0		1	33	0	0
Delivery Problem	0	0	0		0		0	0	0		0		0	0	0	0
Other	4	12	0		0		1	25	0		0		3	75	0	0
Unknown (Optional)	11	33	0		0		0	0	0		0		0	0	11	100
Totals	33		0		0		9	27	0		0		7	21	17	52

<sup>&</sup>quot;Unknown" is based on an unidentifiable source or cause of release.

<sup>&</sup>quot;Other" is an identifiable source or cause of release that does not fit specific locations identified in the chart.